

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 140185

Dated: 19/01/23

It is certified that an inspection team headed by ...Sh. Mukesh Sharma, J. Chemist

(Name of Officers with designation) from ...office of the chief chemist, PHED Lab, Jaipur

(Name of Department/ Office) inspected the Shree Gopi Ram Rudi Devi Sen. Sec. School,

(Name & Address of the school) on 18/01/2023 (date of inspection) and found that the Shyam Nagar, Udaipuria, The-chow, Jaipur

Shree Gopi Ram Rudi Devi Sen. Sec. School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 1 year

Signature with Seal:  19/01/23

Name : मुख्य रसायनज्ञ

Designation : जगत रवो अभि विभाग

Name & Address of the Office / Department : office of the chief chemist, PHED Lab, Jaipur

To

SHREE GOPI RAM RUDI DEVI SEN. SEC. SCHOOL

SHYAM NAGAR, UDAI PURIYA MOD, CHOW, JAIPUR, RAJASTHAN

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, RAJASTHAN, JAIPUR

REPORT OF THE CHEMICAL EXAMINATION OF WATER

Report No.: Raj/DW(Chem)/2022-23/ 25023

Dated: 24/01/2023

Issued To,

Hajari lal yadav

Shree Gopi Ram
Chomu


Rudi Devi Sen. Sec. School, Shyam Naha

District: Jaipur

Block/City: Chomu

Ref_ID :	12	Lab Sample No. :	12		
Reference :Your Letter No.:	SPL/04	Source :	TW		
Reference Dated :	18-01-2023	Source Location :	Shree Gopi Ram Rudi Devi Sen. Sec. School		
Date of Receipt :	19-01-2023	Habitation/Ward No. :	Udaipuria		
Name of Sample Taker :	Hajari lal yadav	Village/Colony/Town :	Shyam Nagar		
Desig. of Sample Taker :	-	Gram Panchayat/City Area :	Chomu		
Latitude :		Date of Collection :	18-01-2023		
Longitude :		Date of Examination :	19-01-2023		
Elevation in Meter :					
Test Parameters	IS-10500:2012		Test Values of Samples		
	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources			
1 pH	6.5 to 8.5	No Relaxation	7.8		
2 Turbidity(NTU)	1	5	Clear		
3 Colour (Hazen Unit)	5	15	None		
4 Odour	Unobjectionable	-	UO		
5 Total Alkalinity (as CaCO ₃)	200	600	220		
6 Total Hardness (as CaCO ₃)	300	600	190		
7 Calcium (as Ca ⁺⁺)	75	200	28		
8 Magnesium (as Mg ⁺⁺)	30	100	29		
9 Chloride (as Cl ⁻)	600	1000	330		
10 Sulphate (as SO ₄ ⁻²)	200	400	55		
11 Nitrates (as NO ₃ ⁻)	45	No Relaxation	35		
12 Fluoride (as F ⁻)	1.0	1.50	0.68		
13 Total Dissolved Solids	500	2000	1190		
14 Residual Chlorine	0.2	0.5	-		

Note:- Report is not valid for Food Licence or any Certificate.


Superintending Chemist
PHED, Lab, Jaipur

Report No: Raj/DW(Chem)/2022-23/
Copy to:

1. The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.
2. Executive Engineer, PHED Division

Dated: 24/01/2023
अधीक्षक रसायनज्ञ
जन स्वा. अभि. विभाग
प्रयोगशाला-जायपुर

Superintending Chemist